

Preliminary Assessment Report

Project 3014237, 2023 30TH AVE W

Assessment Completed: 10/25/2012

Project Description: Variance for previously remodeled garage not be required to be re-converted, and will show adequate parking on site.

Primary Applicant: [Mark Vanvliet](#)

This report lists the results of a preliminary assessment of your project requirements by various city departments. It's based on the project characteristics described on your site plan and preliminary application form. If your project required a pre-application site visit (PASV), the results of that site visit are also included. The goal of this report is to help you create a complete submittal package and reduce the need for corrections once your application has been submitted.

Next Steps

1. Review the requirements in this report and contact the staff members listed below with questions.
2. If a street improvement plan is required, develop and submit it to the Seattle Department of Transportation (SDOT). **The Department of Planning and Development (DPD) will not accept your permit application until your street improvement plan is approved as 60% complete by SDOT. See [SDOT Client Assistance Memo 2213](#) for guidance about the 60% complete approval process.**
3. Schedule an appointment for permit application intake with DPD. **Please bring a copy of this report to your intake appointment.**

Questions About This Report

If you have questions about the information in this report, contact the appropriate city staff member for each section.

DPD Drainage Requirements

Kevin Donnelly, (206) 684-5051, Kevin.Donnelly@seattle.gov

DPD Land Use Requirements

Edgardo R Manlangit, (206) 684-5043, Ed.Manlangit@Seattle.Gov

DPD Preapplication Site Visit Requirements

Arthur Thomas Richardson, (206) 233-3875, art.richardson@seattle.gov

Seattle City Light Requirements

Maneet Jain, (206) 684-3396

Seattle Department of Transportation Requirements

Tammy Frederick, tammy.frederick@seattle.gov

Seattle Public Utilities Requirements

Jennyfer Jacobsen, (206) 684-8766, JacobsJS@seattle.gov

Water Availability

K Younge, (206) 684-5975, Karen.Younge@Seattle.Gov

Other Resources

- General questions about the permit process: Contact the DPD Applicant Services Center (ASC) at 206-684-8850.
- Overview of the permit application process: [5 Steps for a Successful DPD Application Submittal](#).
- User-friendly guides to city permitting processes: [DPD](#) and [SDOT](#) Client Assistance Memos.
- [Detailed zoning information](#).
- [DPD's Checklists & Standards](#), designed to help you make sure your permit application is complete and ready for review.

Requirements

DPD Drainage Requirements

The following requirements are based on the current stormwater and side sewer codes.

Existing Public Drainage Infrastructure

Sanitary sewer main location: 30th Ave W

Sanitary sewer main size: 8-inches

Storm drainage main location: Condon Way W

Storm drainage main size: 15-inches

Drainage

The drainage point of discharge (SMC 22.805.020) is located at: Weep hole.

Permanent and Temporary Dewatering

The footing drain (if part of building plan) point of discharge (DPD DR 4-2011) is located at the following: Onsite (infiltration).

DPD Land Use Code Requirements

Street Requirements

Based on the scope of the proposed project, the following street improvements are required per Chapter 23.53 of the Seattle Municipal Code. Please review Right-of-Way Improvements Manual for design criteria (<http://www.seattle.gov/transportation/rowmanual/manual/>). Show required street improvements on your "enhanced site plan" at DPD permit application intake. If an SDOT Street Improvement Plan (SIP) is required, please list SDOT project number and SDOT contact name on the enhanced site plan. Street Improvement Plans must be accepted by SDOT prior to DPD permit application intake.

30TH Ave W

Based on the documents provided, no street improvements are required per SMC 23.53.015 and SMC 23.53.006

Alley Requirements

Along the west PL.

Based on the submitted documents, no alley improvements are required per SMC 23.53.030

Pre-Application Site Visit (PASV) Requirements

PASV report requirements may be subject to additions, changes, or modifications by the department. The purpose of the report is to alert the applicant that there may be unusual or complex site conditions that trigger requirements from the department regarding this project. **The applicant is responsible for providing all required documents at the intake appointment.** If you have questions about this report or the PASV process, please contact the DPD Site Development Team at (206) 684-8860.

Note: Any project application associated with the development site can utilize the results from this PASV if the application is accepted by DPD within 18 months of the above inspection date. After 18 months, the applicant must apply for another PASV. No extensions will be granted.

ECA Mapping Unit and Type

This project site appears to include the following ECAs and/or buffers:

Steep slope

Existing ROW Conditions

30TH Ave W

Street conditions:

Concrete paving

Curb conditions:

Curb adjacent to site

Concrete

Approximate curb height: 5 inches

A storm inlet is located <350 ft from the site and prior to crossing a public right of way.

It appears that drainage from that discharge point will remain in the gutter line all the way to the nearest inlet structure, but this assessment is preliminary and it is the responsibility of the applicant to meet all relevant SW code requirements.

Along the west PL.

Unopened

Potential Impacts to Seattle Parks Property

No parks property in vicinity

Construction Stormwater Control

All projects with earth disturbance, regardless of size, require temporary and permanent stormwater control in accordance with the Construction Stormwater Control (CSC) Technical Requirements Manual (DR 16-2009, Volume 2). The CSC Best Management Practices (BMPs) noted below can be found in the Construction Stormwater Control Technical Requirements Manual, available online and from DPD's Public Resource Center.

Show the following on the CSC/Post Construction Soil Amendment Plan:

Place compost socks, compost berms, filter fabric fencing, straw bales, straw wattles, or other approved perimeter control BMPs to eliminate construction stormwater runoff.

Show the location of a stabilized construction access to the site; show methods to eliminate uncontrolled conveyance of mud and dirt into the right of way (ROW).

Cover bare soil with compost blankets, straw, mulch, matting, or other approved equal to control construction stormwater runoff.

Cover stockpiles and bare slopes with compost blankets, tarps, matting or other approved equal to control construction stormwater runoff.

A First Ground Disturbance inspection is required before any ground disturbance related to this permit, including demolition, tree cutting, clearing, grubbing, and grading. After your permit is issued, schedule an inspection by calling (206) 684-8900 or online at: <http://web1.seattle.gov/DPD/InspectionRequest>

Inspectors Notes

Site slopes down to the west. Project appears to qualify for a small project waiver below.

Small Project Waivers (See CAM 327B)

Small project waivers may be applicable for new accessory structures or additions to buildings on lots in existence on or before October 31, 1992 (see SMC25.09.055). Rockeries and retaining walls do not qualify for small project waivers. Applicability of small project waiver must be evaluated and approved at the time of intake.

Cumulative development area is less than or equal to the following:

Steep slope areas/steep slope buffers: Development area less than 300 square feet

Potential slide due to geological conditions, flood prone areas, potential liquefaction, landfill/landfill buffers: Development area less than 750 square feet

In all cases, show construction safety fencing separating the ECA and/or its buffer from the development area.

Standard Submittal Requirements for Projects in an ECA

Seattle City Light Requirements

Notes to Applicant

If an electric service is needed: please contact the Electrical Service Representative for your area several months before new service is required to determine your electric service design, service location and what

kind of service is available at the building site. Your Electrical Service Representative is: Chau Luu, 206-386-9109, chau.luu@seattle.gov

SDOT Requirements

Based on the information provided at this time, it appears that no street improvements are **required**. All work in the right-of-way requires a permit. Therefore, if you are planning discretionary improvements you should contact SDOT as soon as possible. Be advised that it is the applicant's responsibility to seek guidance from SDOT Street Use should the scope of the project change, or should the applicant become aware of proposed construction in the ROW. Failure to contact SDOT at your earliest convenience could severely impact your project's scope, schedule and budget. This responsibility rests solely with the applicant.

SPU Requirements

Water Availability

Your water availability assessment has been waived.

For all multifamily, commercial, and industrial properties, the requirements for solid waste storage and pickup are outlined in SPU CAM 1301, available on the web at:

http://www.seattle.gov/util/stellent/groups/public/@spu/@csb/documents/webcontent/cos_004542.pdf. For questions about solid waste requirements, contact Liz Kain, (206) 684-4166, Liz.Kain@seattle.gov.

Other Requirements

Other Requirements

Owners of residential property occupied by a tenant who will be displaced by housing demolition, substantial rehabilitation, change of use, or removal of use restrictions may need to obtain a Tenant Relocation License. Refer to DPD CAM 123, Seattle's Tenant Relocation Assistance Ordinance, for further information and instructions or call (206) 684-7979.

If your project involves additions or modification to or demolition of an existing building that contains four or more dwelling units or 4,000 square feet or more of non-residential area, and the building is a designated historic landmark or is 50 years old and meets the criteria set forth in SMC 25.12 for landmark designation, SEPA is required. Please contact the Department of Neighborhoods at (206) 684-0228 or www.seattle.gov/neighborhoods/preservation to determine if your building is a designated landmark or if a referral is necessary to determine if the building meets the criteria in SMC 25.12. Refer to CAM 208 for information regarding the application requirements for a SEPA review and CAM 3000 for information regarding landmarks and historic preservation.

If the scope of your proposed project changes before your DPD intake appointment or SDOT street improvement plan application, the requirements in this report may change. If there are municipal code and ordinance changes before our DPD intake appointment, the project must meet the new code requirements. Additional street improvement requirements may be triggered if a permit application for a development project on adjacent property is also undergoing review.

Please be aware that all persons or companies working within the City limits, including all contractors, subcontractors, permit expeditors and other service providers are required to possess a valid City of Seattle business license. This license is required in addition to any other licenses required by the State of Washington, such as a contractors' license or state business license. For more information about City of Seattle business licenses, please contact inspector Michale Crooks at 206-684-8871, Michale.Crooks@seattle.gov, or visit the [Licensing and Tax Administration Division website](#).